


<b>Property Information</b>			<b>Contractor or Licensed Owner Information</b>		
Building Name			Name		
Address		Address			
City		License #	City	St.	Zip
Contact Person		<input type="checkbox"/> SFM	Phone		
Phone		<input type="checkbox"/> CSLB	Job #		
			Misc.		

**Quarterly Inspections**

I = Inspection    T = Test    M = Maintenance				P = Pass    F = Fail    N/A = Not Applicable			
Item		Description	NFPA 25 CA ed. Reference	Date	Date	Date	Date
1.1	I	Control Valves – Identification Sign	13.3.1				
1.2	I	Control Valves – Inspection	13.3.2				
1.3	I	Hose Houses	7.2.2.7				
1.4	I	Fire Department Connections	13.7				
1.5	I	Pressure Reducing Valves	13.5.1.1				
1.6	I	Backflow Preventers	13.6.1				
1.7	I	Supervisory Devices	13.3.3.5.1				
1.8	I	Monitor Nozzles	7.2.2.6				

**ANNUAL INSPECTION, TESTING, AND MAINTENANCE**  
*Include ALL Quarterly Inspections*

I = Inspection    T = Test    M = Maintenance				P = Pass    F = Fail    N/A = Not Applicable		
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
1.9	I	Hydrants (Dry Barrel and Wall)	7.2.2.4 Table 7.2.2.4			
1.10	I	Hydrants (Wet Barrel)	7.2.2.5 Table 7.2.2.5			
1.11	I	Mainline Strainers	7.2.2.3 Table 7.2.2.3			
1.12	I	Piping (Exposed)	7.2.2.1 Table 7.2.2.1.2			
1.13	I	Piping (Underground)	7.3.1			
1.14	I	Hose	NFPA 1962			
2.1	T	Control Valve - Position	13.3.3.1			
2.2	T	Control Valve - Operation	13.3.3			
2.3	T	Monitor Nozzles	7.3.3			
2.4	T	Hydrants - Flush	7.3.2			
2.5	T	Supervisory Devices	13.3.3.5			
2.6	T	Backflow Preventer Assemblies	13.6.2			
2.7	T	Pressure Reducing Valve (Partial Flow Test)	13.5.1.3			
3.1	M	Control Valves	13.3.4			
3.2	M	Mainline Strainers	7.2.2.3			

